


Hesco

emailed



TRANSMITTAL (MATERIAL)

Submit Resubmit

Date 24/9/2022	Project Code Hesco MBL	Project Title GOLF CLUB HOUSE	Transmittal No. HESCO-CLUB HOUSE-MAT-EE-087-Rev-02
--------------------------	-------------------------------------	---	--

DISCIPLINE

AR CV ST ME EE LC LS HS

To Resident Engineer Head Office Others

From Main Contractor: MBL, Sub Contractor: First Fix

CONTRACTOR USE

Location: Basement First Floor Ground Floor General Exterior

Item No.	Division	Item Description (Name, Type, Size, Capacity, Specific Use, Etc.)	Manufacturer	Catalog No. Brochure No., Others	No. of Copies
1	EE	Floor Outlets & Floor Sockets for Club house (With Sample)	Double A	FSD	1
				Soft Copy - (CD)	1



Submitted by

Name: <u>Basel Draki</u>	Title: <u>MEP Manager (FF)</u>	Signature: <i>[Signature]</i>
Name: <u>Ashraf El Saey</u>	Title: <u>Technical Manager (FF)</u>	Signature: <i>[Signature]</i>
Name: <u>Mohammad Abdul Azeem</u>	Title: <u>Technical Engineer (MBL)</u>	Signature: <i>[Signature]</i>
Name: <u>Ramadan Ewaida</u>	Title: <u>Electrical Engineer (MBL)</u>	Signature: <i>[Signature]</i>
Name: <u>Carlos Sebastia</u>	Title: <u>GCH Project Manager (MBL)</u>	Signature: <i>[Signature]</i>
Name: <u>Ahmed Negrn</u>	Title: <u>QC Manager (MBL)</u>	Signature: <i>[Signature]</i>
Name: <u>Ahmed Mansour</u>	Title: <u>Tech. Director (MBL)</u>	Signature: <i>[Signature]</i>
Name: <u>Ahmed Hegazy</u>	Title: <u>Project Manager (MBL)</u>	Signature: <i>[Signature]</i>

Enclosures: 1, Hard Copy: 1, Soft Copy: 1

DATE: 27/9/22

CONSULTANT USE EL VAR

Item #	1	2	1	2
Code				
Reviewed By	<i>Mostafa</i>	<i>Wahed</i>		

Approved Approved As Noted Amend & Resubmit Rejected

Action Code

1. No Exceptions Taken
2. Make Corrections as Noted
3. Amend and Resubmit
4. Rejected

Remarks:

a) Installation shall only proceed when Action Code is 1 or 2.
b) Action Code 3, shall be resubmitted within time limit set in the contract.
c) Review does not relieve the Contractor from Responsibility of Compliance with all requirements of Contract documents.

Special Instructions

Sample submitted is approved Provided that :-

- Finishing color to be exactly as Floor box color attached
- Rubber gland should be installed to cover opening
- Provide single & Doublet as Contractor highlighted for using low part site needs
- All internal modules should be from approved brands in project
- Using only for Flooroutlet (table lamps) [internal only]

Reviewed by: *Mostafa Abu Abuly G-G* *Wahed Mostafa ID/Achit*

Name: *Wahed Mostafa* Title: *ID/Achit* Signature: *[Signature]* Date: *27/9/2022*

Signed off by: _____ Signature: _____ Date: _____